



Certificate of Compliance

Certificate: 70012521

Master Contract: 262135

Project: 70012521

Date Issued: 2015-03-03

Issued to: Thermokey
Via dell'industria, 1
33050 Rivarotta di Teor
Udine - Italy

Attention: Sandro Ortolano

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: Dario Perroni
Dario Perroni

PRODUCTS

CLASS 1223 01 - REFRIGERATION EQUIPMENT - Refrigerant Containing Parts

CLASS 1223 81 - REFRIGERATION EQUIPMENT - Refrigerant Containing Parts - Certified to U.S. Standards

Microchannel coil, intended for use as Condenser or Evaporator coils, with a design pressure and maximum abnormal pressure of 652.6 psi (4500 kPa). The maximum continuous operating temperature is 250°F (121 °C).

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 140.3
UL 207

Refrigerant-Containing Components for Use in Electrical Equipment.
Refrigerant-Containing, Components and Accessories, Non electrical.



Supplement to Certificate of Compliance

Certificate: 70012521

Master Contract: 262135

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70012521	2015-03-03	Original Certification of Refrigerant Containing Components, Microchannel coil, intended for use as Condenser or Evaporator coils, with a design pressure and maximum abnormal pressure of 652.6 psi (4500 kPa). The maximum continuous operating temperature is 250°F (121 °C).